

SCHEDULES

SCHEDULE 2

REQUIREMENTS

Combined heat and power

20.—(1) Prior to the date of final commissioning, a review of potential opportunities for the use of heat from the authorised development must be submitted to and approved by the relevant planning authority.

(2) The review shall provide for the on-going monitoring and full exploration of potential opportunities to use heat from the authorised development and for the provision of subsequent reviews of such opportunities as necessary.

(3) Where viable opportunities for the use of heat are identified, a scheme for the provision of the necessary plant and pipework to the boundary of Work No. 1 shall be submitted to and approved by the relevant planning authority; any plant and pipework installed up to the boundary of Work No.1 to enable the use of heat shall be installed in accordance with the agreed details.