

## SCHEDULE 1

### AUTHORISED DEVELOPMENT

#### Commencement Information

**II** Sch. 1 in force at 3.4.2019, see art. 1

**Work No. 1B** development comprising a generating station and gas and electrical infrastructure including—

- (a) a control room/office/workshop;
- (b) telemetry apparatus;
- (c) a fire water tank;
- (d) a demineralised water storage tank;
- (e) an emergency generator including fuel storage tank;
- (f) gas pipeline and telemetry cabling and cathodic protection test/ transformer rectifier unit;
- (g) a natural gas receiving station and gas treatment compound containing—
  - (i) a pipeline inspection gauge (PIG) receiving facility;
  - (ii) isolation valves, metering, heating, filtering, compression, pressure regulation equipment;
  - (iii) electricity supply kiosks;
  - (iv) emergency generator including fuel storage tank;
  - (v) Joule-Thomson boiler(s); and
  - (vi) control and instrumentation kiosks,

**Status:**

Point in time view as at 09/04/2020.

**Changes to legislation:**

There are currently no known outstanding effects for the The Millbrook Gas Fired Generating Station Order 2019.