

Status: This is the original version (as it was originally made). This item of legislation is currently only available in its original format.

SCHEDULE 1

Amendments to Commission Regulation (EU) 2016/631

19.—(1) Article 25 (voltage stability requirements applicable to AC-connected offshore power park modules) is amended as follows.

(2) Omit paragraph 2.

(3) In paragraph 3—

(a) omit the words from “Notwithstanding the provisions” to “Continental Europe synchronous area”;

(b) for Table 10 substitute—

“Table 10

<i>Synchronous area</i>	<i>Voltage range</i>	<i>Time period for operation</i>
Great Britain	0.90 pu – 1.10 pu where the voltage base for pu values is below 300kV	Unlimited
	0.90 pu – 1.05 pu where the voltage base for pu values is from 300kV to 400kV	Unlimited
	1.05 pu – 1.10 pu where the voltage base for pu values is from 300kV to 400kv	15 minutes”

(4) In paragraph 5, for Table 11 substitute—

“Table 11

Parameters for Figure 8

<i>Synchronous area</i>	<i>Maximum range of Q/P_{max}</i>	<i>Maximum range of steady-state voltage level in PU</i>
Great Britain	0, at the offshore connection point for configuration 1 (as described in Article 23(3)(a)).	0.225
	0.33, at the offshore connection point for configuration 2 (as described in Article 23(3)(b)).	0.225”