

## SCHEDULES

### SCHEDULE 12

Schedule 2, Requirement 5

#### DESIGN PARAMETERS

##### Commencement Information

**II** Sch. 12 in force at 1.9.2020, see [art. 1](#)

[<sup>F1</sup>Table 9

<i>(1)</i> <i>Building or structure</i>	<i>(2)</i> <i>Maximum length (metres)</i>	<i>(3)</i> <i>Maximum width (metres)</i>	<i>(4)</i> <i>Maximum height (metres above 0 meters above ordnance datum)</i>	<i>(5)</i> <i>Maximum diameter (metres)</i>
Single gas turbine and generator	31	20	20	
Gas turbine building	50	35	29	
Exhaust stack			56	12
Air intakes	24	16	40	
Fin-fan cooler	30	15	17	
Control room, workshops, stores	35	20	16	
Demineralised tank, firewater tank			32	24]

##### Textual Amendments

**F1** Sch. 12 table substituted (28.3.2024) by [The Immingham Open Cycle Gas Turbine \(Amendment\) \(No. 2\) Order 2024 \(S.I. 2024/446\)](#), arts. 1, 3

**Changes to legislation:**

There are currently no known outstanding effects for the The Immingham Open Cycle Gas Turbine Order 2020, SCHEDULE 12.