

## SCHEDULE 1

### Authorised Project

## PART 3

### Requirements

#### Detailed offshore design parameters

- 6.—(1) In relation to a wind turbine generator, each foundation using piles must not have—
- (a) more than four driven piles;
  - (b) in the case of single pile structures, a pile diameter which is more than 15 metres; or
  - (c) in the case of two or more pile structures, have a pile diameter which is more than five metres.
- (2) In relation to a wind turbine generator, each foundation must not have a seabed footprint area (excluding scour protection) of greater than 1,963m<sup>2</sup>.

---

#### Commencement Information

- II** Sch. 1 Pt. 3 para. 6 in force at 1.1.2022, see [art. 1](#)

**Changes to legislation:**

There are currently no known outstanding effects for the The Norfolk Boreas Offshore Wind Farm Order 2021, Paragraph 6.