

SCHEDULE 1

Authorised Project

PART 3

Requirements

Detailed offshore design parameters

- 8.—(1) In relation to an offshore electrical platform, each foundation using piles must not have—
- (a) more than 18 driven piles; or
 - (b) in the case of two or more pile structures, have a pile diameter which is more than five metres.
- (2) In relation to the offshore electrical platform(s), the foundations must not have a combined seabed footprint area (excluding scour protection) of greater than 15,000 m².

Commencement Information

II Sch. 1 Pt. 3 para. 8 in force at 1.1.2022, see [art. 1](#)

Changes to legislation:

There are currently no known outstanding effects for the The Norfolk Boreas Offshore Wind Farm Order 2021, Paragraph 8.