
STATUTORY INSTRUMENTS

2024 No. 446

The Immingham Open Cycle Gas Turbine
(Amendment) (No. 2) Order 2024

Amendment to Schedule 12 (design parameters)

3. For the table in Schedule 12, substitute—

“Table 9

| <i>(1)</i> <i>Building or structure</i> | <i>(2)</i> <i>Maximum length (metres)</i> | <i>(3)</i> <i>Maximum width (metres)</i> | <i>(4)</i> <i>Maximum height (metres above 0 metres above ordnance datum)</i> | <i>(5)</i> <i>Maximum diameter (metres)</i> |
|--|--|---|--|--|
| Single gas turbine and generator | 31 | 20 | 20 | |
| Gas turbine building | 50 | 35 | 29 | |
| Exhaust stack | | | 56 | 12 |
| Air intakes | 24 | 16 | 40 | |
| Fin-fan cooler | 30 | 15 | 17 | |
| Control room, workshops, stores | 35 | 20 | 16 | |
| Demineralised tank, firewater tank | | | 32 | 24” |