

## SCHEDULE 2

Requirements for spring water and drinking water  
including prescribed concentrations or values of parameters

### **PART 1**

Requirements for spring water and drinking water

1. Water satisfies the requirements of this Schedule if —
  - (a) the water does not contain —
    - (i) any micro-organism (other than a parameter) or parasite, or
    - (ii) any property, element or substance (other than a parameter),at a concentration or value which would constitute a potential danger to human health;
  - (b) the water does not contain any substance (whether or not a parameter) at a concentration or value which, in conjunction with any other property, element, substance or organism it contains (whether or not a parameter), would constitute a potential danger to human health;
  - (c) the water does not contain concentrations or values of any of the parameters listed in Tables A to D in Part 2 of this Schedule in excess of the prescribed concentrations or values; and
  - (d) in the case of water prepared from water which has been softened or desalinated, its hardness is not below a minimum concentration of 60 mg Ca/l.
2. The concentrations or values of the parameters listed in Tables A to D in Part 2 of this Schedule must be read in conjunction with the notes thereto.