

SCHEDULE 2

Monitoring

PART 3

Minimum frequency for both check monitoring and
audit monitoring for water put into bottles or containers

<i>Volume¹ of water produced in bottles or containers each day (m³)</i>	<i>Check monitoring number of samples per year</i>	<i>Audit monitoring number of samples per year</i>
≤ 10	1	1
$>10 \leq 60$	12	1
> 60	1 for each 5 m ³ /day of the total volume (rounding up to the nearest multiple of 5 m ³ /day)	1 for each 100 m ³ /day of the total volume (rounding up to the nearest multiple of 100 m ³ / day)

1 The volumes are calculated as averages taken over a calendar year.