

---

WELSH STATUTORY INSTRUMENTS

---

**2017 No. 1041**

**The Private Water Supplies (Wales) Regulations 2017**

**PART 2**

**Monitoring**

**Other private supplies including supplies as part of a domestic tenancy**

**11.**—(1) In the case of a private water supply not covered by regulation 8, 9 or 10, the local authority must monitor for—

- (a) conductivity;
- (b) enterococci;
- (c) *Escherichia coli* (*E. coli*);
- (d) hydrogen ion concentration;
- (e) turbidity;
- (f) any parameter in Part 1 or 2 of Schedule 1 identified in the risk assessment as being at risk of not complying with the concentrations or values in those Parts of that Schedule; and
- (g) anything else identified in the risk assessment as a potential danger to human health.

(2) The local authority must carry out the monitoring required by this regulation at least every 5 years and more frequently if the risk assessment shows this to be necessary.