

## SCHEDULE 4

### Sampling and analysis

#### PART 3

##### Monitoring for indicative dose and analytical performance characteristics

##### Screening for certain radionuclides, or screening for an individual radionuclide

**8.** If one of the activity concentrations exceeds 20% of the corresponding derived value or the tritium concentration exceeds its parametric value listed in Part 3 of Schedule 1 an analysis of additional radionuclides is required.

---

##### Commencement Information

**11** Sch. 4 para. 8 in force at 20.11.2017, see [reg. 1](#)

**Changes to legislation:**

There are currently no known outstanding effects for the The Private Water Supplies (Wales) Regulations 2017, Paragraph 8.