
OFFERYNNAU STATUDOL CYMRU

2018 No. 558

**Rheoliadau Rheoliadau Adeiladu etc. (Diwygio)
(Adeiladau Ynni a Eithrir) (Cymru) 2018**

RHAN 2

Rheoliadau Adeiladu 2010

Atodlen 4 (disgrifiadau o'r gwaith pan na fo'n ofynnol rhoi hysbysiad adeiladu nac adneuo planiau llawn)

16.—(1) Ym mharagraff 1—

(a) ar ôl “work consisting of” mewnosoder—

“(a) replacing any fixed electrical equipment which does not include the provision of—

(i) any new fixed cabling, or

(ii) a consumer unit;

(b) replacing a damaged cable for a single circuit only;

(c) re-fixing or replacing enclosures of existing installation components, where the circuit protective measures are unaffected;

(d) providing mechanical protection to an existing fixed installation, where the circuit protective measures and current carrying capacity of conductors are unaffected by the increased thermal insulation;

(e) installing or upgrading main or supplementary equipotential bonding.”;

(b) yn is-baragraff (g)—

(i) ym mharagraff (i) hepgorer “(other than a fixed flueless gas cooker)”;

(ii) ym mharagraff (ii) yn lle “12(6A)” rhodder “12(6)(b)”.

(2) Ar ôl paragraff 1 mewnosoder—

“2. Work which—

(a) is not in a kitchen, or a special location;

(b) does not involve work on a special installation; and

(c) consists of—

(i) adding light fittings and switches to an existing circuit, or

(ii) adding socket outlets and fused spurs to an existing ring or radial circuit.

3. Work on—

(a) telephone wiring or extra-low voltage wiring for the purposes of communications, information technology, signalling, control and similar purposes, where the wiring is not in a special location;

- (b) equipment associated with the wiring referred to in sub-paragraph (a);
- (c) pre-fabricated equipment sets and associated flexible leads with integral plug and socket connections.”

(3) Ym mharagraff 4 mewnosoder yn y manau priodol—

““kitchen” means a room or part of a room which contains a sink and food preparation facilities;”;

““special installation” means an electric floor or ceiling heating system, an outdoor lighting or electric power installation, an electricity generator, or an extra-low voltage lighting system which is not a pre-assembled lighting set bearing the CE marking referred to in regulation 39 of the Electrical Equipment (Safety) Regulations 2016” (1);”;

““special location” means a location within the limits of the relevant zones specified for a bath, a shower, a swimming or paddling pool or a hot air sauna in the Wiring Regulations, seventeenth edition, published by the Institution of Electrical Engineers and the British Standards Institution as BS 7671: 2008(2).”

(1) [O.S. 2016/1101](#).

(2) [ISBN 978-0-86341-844-0](#).