

## SCHEDULE

### Conditions

## PART 1

### Conditions of building operations

#### **Lighting**

**10.**—(1) Lighting units must be placed as low to the ground as is practicable and lighting columns must not exceed 15 metres in height from ordinance datum.

(2) Lighting units must be—

- (a) hooded in order to hide the light source from view from outside the developable area, and
- (b) directed downwards in order to minimise light spill.

(3) Artificial light levels must not exceed 0.74 lux when measured at 1 metre outside the boundary of the developable area.

(4) The correlated colour temperature of each artificial light must not exceed 2700 kelvin.

(5) Blue spectrum lighting from any source must not be visible from the rocky outcrop.